



State of Utah

Division of Facilities Construction and Management
4130 State Office Building Salt Lake City, Utah 84114-1002
Phone: 801-538-3263 Fax: 801-538-3378

HEDCO BUILDING ROOFING AND SEISMIC IMPROVEMENTS

UNIVERSITY OF UTAH

Project Number: 03088750

Addendum Number 1

April 15, 2004

Information contained within this addendum should be considered in preparing proposal.

Index to Addendum Number 1

**This cover
&
1 page**

Project # 03088750
Addendum Number 1
April 15, 2004

The following items apply to this project after considering questions and concerns at the project pre bid meeting.

- 1- The schedule has been modified as follows
 - a- Final questions are due on April 19, 2004 by 4:00 P.M.
 - b- The Final addendum will be issued by April 21, 2004 by 4:00 P.M.
 - c- The Bid Date for the project will be April 28, 2004 at 3:00 P.M.
 - d- The Subcontractors list will be due April 29, 2004 by 3:00 P.M.
- 2- Standing seam joints will be required on all new coping. Flat joints will not be acceptable.
- 3- New riglets for counter flashing may be surface mounted, saw cut will not be required.

Direct any concerns or Questions about project to Darrell Hunting @ 801-244-7647